

CMG-3T CALIBRATION SHEET

WORKS ORDER: 5169 DATE: 27-Jul-2009

SERIAL NUMBER: T36047 TESTED BY: S. Goddard

	Velocity Output V/m/s (Differential)	Mass Position Output (Acceleration output) V/m/s ²	Feedback Coil Constant Amp/m/s ²
VERTICAL	2 x 743	1757	0.02342
NORTH/SOUTH	2 x 749	1993	0.02657
EAST/WEST	2 x 752	1964	0.02618

Power Consumption: 60mA @ +12V input
Calibration Resistor: 51000

NOTE: A factor of 2 x must be used when the sensor outputs are used differentially (also known as push-pull or balanced output). Under no conditions should the negative outputs be connected to the signal ground. A separate signal ground pin is provided.

POLES AND ZEROS TABLE

WORKS ORDER NUMBER: 5169

SENSOR SERIAL NO: T36047

Velocity response output, Vertical Sensor:

<u>POLES (HZ)</u>	<u>ZEROS HZ</u>
$-5.89 \times 10^{-3} \pm j5.89 \times 10^{-3}$	0
-180	0
-160	
-80	

Normalizing factor at 1 Hz: A = 2304000

Sensor Sensitivity: See Calibration Sheet.

Velocity response output, Horizontal Sensors:

<u>POLES (HZ)</u>	<u>ZEROS (HZ)</u>
$-5.89 \times 10^{-3} \pm j5.89 \times 10^{-3}$	0
-180	0
-160	
-80	

Normalizing factor at 1 Hz: A = 2304000

Sensor Sensitivity: See Calibration Sheet.

NOTE: The above poles and zeros apply to the vertical and the horizontal sensors and are given in units of Hz. To convert to Radian/sec multiply each pole or zero with 2π . The normalizing factor A should also be recalculated.